

BUREAU OF INSPECTIONS

Phone: (610) 865-7091

Fax: (610) 865-7330

TDD: (610) 865-7086

Agenda

Code Board of Appeals
Thursday, May 25, 2023 @ 3:30pm

Town Hall
10 East Church Street, Bethlehem, PA 18018

1. 209 East Broad St, Bethlehem, PA seeking relief from:
Article 240.24 of the National Electrical Code 2014 edition
Location on Premises

(B) Each occupant shall have ready access to all overcurrent devices protecting the conductors supplying that occupancy, unless otherwise permitted in 240.24(B)(1) and (B)(2).

(1) Service and Feeder Overcurrent Devices.

Where electric service and electrical maintenance are provided by the building management and where these are under continuous building management supervision, the service over current devices and feeder overcurrent devices supplying more than one occupancy shall be permitted to be accessible only to authorized management personnel in the following:

(1) Multiple- Occupancy buildings

(2) Guest rooms or guest suites

(2) Branch-Circuit Overcurrent Devices.

Where electric service and electrical maintenance are provided by the building management and where these are under continuous building management supervision, the branch-circuit overcurrent devices supplying any guest rooms or guest suites without permanent provisions for cooking shall be permitted to be accessible only to authorized management personnel.

Applicant must be present for appeal to be heard.

