

BUREAU OF INSPECTIONS

Phone: (610) 865-7091

Fax: (610) 865-7330

TDD: (610) 865-7086

Agenda

Code Board of Appeals
Thursday June 29, 2023 @ 2:30pm

Town Hall
10 East Church Street, Bethlehem, PA 18018

1. 3633 Commerce Center Blvd, Bethlehem, PA seeking relief from:
NFPA 13 14.2.11.4 (1) Conveyors of the 2022 Edition of NFPA 13
14.2.11.4 Conveyors. Sprinklers shall be arranged with respect to conveyors in accordance with one of the following:
 - (1) Quick-response standard spray sprinklers shall be permitted to be installed below conveyors without high-piled storage located underneath.

*It should be noted that the forthcoming **2022 NFPA 13** does allow for conditions similar to what the design professional's are proposing.

Applicant must be present for appeal to be heard.

