

**CITY OF BETHLEHEM**  
**INTER-DEPARTMENTAL CORRESPONDENCE**

**SUBJECT:** Request for Approval by City Council of Contract Award or Contract Price Increase Pursuant to City Ordinance, Article 121.05 (a)

Project or Contract Reference: 2021 29 GC WWTP W. Influent Pump Room  
Upgrades

**TO:** City Council, all members, and Council Solicitor

**FROM:** Edward J. Boscola, P.E.  
Director of Water & Sewer Resources

**DATE:** October 31, 2023

---

On behalf of the Administration, pursuant to City Ordinances, Article 121.05, I request City Council's approval of the following recommendation of the referenced contract award or price increase.

- Check Type of Contract or Change:

\_\_\_\_\_ The contract is for over \$50,000 and required to be bid under the Third Class City Code. We have advertised the above referenced project and received qualified bids. We recommend award of the contract to the bidder identified and for the reasons stated below.

  X   The recommendation is for a price increase of 10% or more for an existing contract over \$50,000 that was previously bid and awarded under the Third Class City Code.

\_\_\_\_\_ The contract is for the engagement of professional services. We have received a proposal for professional services in connection with above referenced project.

- Is the contract appropriation or price increase included in this year's budget?   X   yes   \_\_\_ no
- Identify contract funding sources (general fund, grants, loans, etc.....):  
*Sewer Capital - 008A-88123*
- The name and address of the recommended Contractor:  
*Eastern Environmental Contractors, Inc. – 6304 5th St, PO Box 278, Green Lane, PA 18054*
- Term of contract or estimated completion date, subject to standard extensions:

Substantial Completion – February 29, 2024  
Final Completion – March 31, 2024

- Description of project or scope of services to be provided:

Complete the following work items for the WWTP West Influent Pump Room Upgrade Project. Install 2<sup>nd</sup> flood control door & access hatches, wall plate, additional demolition, isolation valve replacement, east pump room control upgrades, and east wet well cleaning. Installation of flexible connectors on the West Influent Pumps to reduce vibration and associated vibration testing.

- State the actual or estimated price to the City or the proposed Department budget allowance for the initial term; and state payment rate per unit of service if applicable:

Original Contract Amount = \$1,341,300.00

Proposed Change Order = \$148,437.00

Total Proposed Cost = \$1,489,737.00

- Number of renewal term options and duration of each renewal, if any:

N/A

- Maximum dollar value of all renewals provided for beyond the original term as if all renewals were exercised:


N/A

- Reasons for recommendation of Administration and Council approval of contract:

Owner requested changes to address unforeseen conditions and additional work items to improve system performance.

Please approve this recommendation by passing the accompanying resolution. A vote of final approval is requested at the first City Council agenda listing of this matter.

---

By:   
Edward J. Boscola, P.E.  
Department Head – Water & Sewer Resources

Copies To: Mayor  
Director of Administration  
Director of Budget and Finance  
Law Bureau  
Purchasing Bureau  
Controller  
Project Manager  
Attachment: proposed resolution

RESOLUTION NO. \_\_\_\_\_

Authorization for Contract or Amendment under Article 121.05(a)

BE IT RESOLVED by the Council of the City of Bethlehem that the Mayor and the Controller and/or such other City officials as deemed appropriate by the City Solicitor, are hereby authorized to execute a Contract or Amendment and such other agreements and documents as are deemed by the City Solicitor to be necessary and/or related thereto, with the following named contractor, for the uses and purposes indicated in the supporting Recommendation of Award of Bid or Contract.

1. Name of Contractor:

Eastern Environmental Contractors, Inc.  
6304 5th St, PO Box 278, Green Lane, PA 18054

2. Project or Contract Reference:

2021 29 GC WWTP W. Influent Pump Room Upgrades

Sponsored by \_\_\_\_\_

\_\_\_\_\_

ADOPTED by Council this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_.

\_\_\_\_\_  
President of Council

ATTEST:

\_\_\_\_\_  
City Clerk