



CITY OF BETHLEHEM

10 East Church Street, Bethlehem, Pennsylvania 18018-6025

BUREAU OF PLANNING AND ZONING

Phone: 610-865-7088

Fax: 610-865-7330

TDD: 610-865-7086

January 3, 2025

Hanover Rauch LLC.



RE: (24-006 Sketch Plan Review) – 24120001 – 312 HANOVER STREET – SKETCH PLAN REVIEW – Ward 10, Zoned RT, plans dated October 11, 2024.

Dear Sir,

The above-referenced plan has been reviewed by the appropriate City offices. A Sketch Plan lacks much of the information necessary for a thorough evaluation and has been reviewed only for general conformance to City of Bethlehem standards to the extent permitted by the limited detail provided. Additional comments will be provided when a more detailed plan is submitted for review.

At this point we offer the following sketch plan comments:

1. Provide elevations for the proposed new structure and indicate building height and label exterior finishes.
2. Indicate what measures shall be employed for tree protection for the adjacent mature tree along the north lot line and in common with the parcel located at 315 Rausch Street.
3. Rausch Street adjacent to the subject parcel is 12' in width, and one-way from Spring Street to Filbert Street. The Applicant shall prove to the satisfaction of the City Engineer and Fire Marshall that vehicle turning movements can be accommodated on and off the site; see also comments from the Traffic Superintendent. The Applicant shall install all traffic controls necessary to allow for the safe passage of vehicles along Rausch Street between Spring Street and Filbert Street.
4. The habitable floor area of the half story appears to exceed 50 percent of the habitable floor area of the story next below, and therefore does not meet the Zoning Ordinance definition of a 'Half-Story,' Ref. §1302.54. Applicant shall verify floor area calculations or submit for a dimensional variance.

Additional comments to be addressed at the Subdivision & Land Development Plan review stage are attached.

This plan will be placed on the January 9, 2025 Planning Commission agenda. Please let us know who will be attending in person. As a sketch plan submission, no formal action is required from the Planning Commission, but since this plan qualifies for Site Plan review, Ref. 1322.03(zz)(6), then they may make recommendations to the Zoning Hearing Board, as applicable, regarding the overall plan

Sincerely,

Darlene L. Heller, AICP
Assistant Director of Planning and Zoning

- | | | | | |
|----|------------------|-------------------|-------------|------------------------|
| C. | Basel Yandem | Olivia Teel | Greg Cryder | James Preston, Esq. |
| | David Taylor | Mike Halbfoerster | Ryan Knause | Broughal & DeVito, LLP |
| | Geoffrey Karanja | Robert Taylor | Craig Baer | |

Enclosure

Additional Comments Related to the Overall Land Development

PUBLIC WORKS

Engineering

1. Existing and proposed features, including, but not limited to, utilities, profiles, landscaping, lighting and details shall be shown on separate plans.
2. Existing and proposed lot monuments/iron pins including benchmark shall be shown.
3. Any deficient sidewalk along the entire property must be removed and replaced. Curbing along Hanover Street may also be required to be replaced and will be evaluated at the time of land development review.
4. Applicant shall modify the plans to show new curb and sidewalk along Rauch Street.
5. In accordance with Ordinance No. 4342, at the time of a request for a building permit or at the execution of the developer's agreement, a sanitary sewer tapping fee of \$2,527 per EDU will need to be paid. The total amount will be determined when a sanitary sewer facilities planning module application is submitted. A cover letter, describing the project, and a utility plan shall be included in the planning module submittal. Please note that building permits cannot be issued until the Planning Module is reviewed and approved by the Pennsylvania Department of Environmental Protection.
6. The following notes are required on the land development plans:
 - a. By submission of these plans the engineer on record certifies that these plans are in complete conformance with the City of Bethlehem Storm Water Management Ordinance.
 - b. In order to maintain continuity between plan revisions, any changes to a previous plan submission shall be flagged with a triangle. Any changes not flagged may be considered not approved. Flagged changes shall be referenced to the appropriate revision date in the revision block.
 - c. Accurate as-built plans shall be kept up to date during the construction process. At the completion of the project record drawings shall be developed from the as-built plans and submitted to the City Engineer's Office. All final drawings shall show North American Datum (NAD) 1983 State Plane Coordinates in feet (Pennsylvania South, FIPS Zone 3702) and the digital file shall be in State Plane Feet Coordinates as applicable. The hard copy of the record drawings shall be in the form of a Mylar copy. The engineer of record shall certify (i.e., P.E. stamped and signed) that the record drawings comply substantially with the approved plan and that they conform to industry standards. All digital files shall reside on USB flash drive containing the digital representation of the final plan as presented on the twenty-four (24) inch by thirty-six (36) inch sheets. The digital map shall be AutoCAD compatible. All layers included in the digital maps shall be the standardized layers prepared and utilized by the City of Bethlehem to ensure compatibility with the City's existing CAD standards and as described in Appendix A of the City's Subdivision and Land Development Ordinance.
 - d. Prior to any work within the Right-of-Way, permits must be obtained from City Engineering Office.

Traffic

1. Trip generation calculations will need to be submitted for the plan, so that it can be determined whether a traffic study is required per the SALDO requirements.
2. Rauch Street is a one-way street, the driveway will have to be left only when exiting. This and other applicable signage will have to be included on a sign schedule.

Forestry

1. Submit a landscape plan for review.

Electrical

1. Show light fixtures on the plan and indicate how illumination will be provided at the driveway entrance from Rausch Street and the four parking spaces on the property.

FIRE

The City of Bethlehem Fire Department currently enforces the 2018 Edition of the International Fire Code in its entirety including Appendices, with local amendments, as adopted in Article 1501 of the Codified Ordinances of the City of Bethlehem, Ordinance 2022-15.

A condensed version of Article 1501/Ordinance 2022-15 listing the common items that affect Land Development Projects is attached at the end of this document for reference. For a copy of the full ordinance please visit <https://www.bethlehem-pa.gov/CityOfBethlehem/media/BFDMedia/Fire-Code.pdf>

1. Indicate if the building is planned to be sprinklered. If the building is to be sprinklered, then indicate the proposed location of all Fire Department Connections (FDC). Fire department connections shall be located on the street side of buildings, fully visible and recognizable from the street or nearest point of fire department vehicle access or as otherwise *approved* by the Fire Marshal. Add a note to the plan stating: "Any change in the location of the Fire Department Connection shall be approved by the City of Bethlehem Fire Department."
2. All 'Fire Lanes' or "Fire Department Access Roads" must be identified and properly marked (Refer to International Fire Code, 2018 ed., Section 503 and Appendix D for additional information). Locations for signs and markings can be determined as the project progresses.
3. Indicate the proposed building height. All buildings less than 30 feet in height must have 20 foot wide, minimum, access road(s). All buildings 30 feet or greater in height must have 26 foot wide, minimum, access road(s) and must accommodate a fire apparatus weighing 84,000lbs (Refer to International Fire Code, 2018 ed., Section 503 and Appendix D for additional information). At least one of the required access roads meeting this condition shall be located within a minimum of 15 feet (4572 mm) and a maximum of 30 feet (9144 mm) from the building, and shall be positioned parallel to one entire side of the building (Refer to International Fire Code, 2018 ed., Section 503 and Appendix D for additional information).
4. The architect/engineer must confirm Fire Department apparatus will be able to drive on all road surfaces without contacting the driving surface. Check angles of approach and departure to confirm that the front and rear apparatus bumpers will not contact the driving surface. Also confirm that the middle of the truck will not contact the driving surface of humps or crowns such as on speed bumps (Refer to International Fire Code, 2018 ed., Section 503 and Appendix D for additional information).
5. Add a note to plan acknowledging that Chapter 33 of the IFC "Fire Safety During Construction and Demolition" will be enforced for the duration of the construction project.
6. The following drawings are required to be submitted for Fire Department Review of Land Development Plans:
 - a. Utility plan including water supply showing fire hydrants on or near the property.
 - b. Turning Plan.
 - c. Site Plan.
 - d. Grading Plan.
 - e. Elevation Drawing, or other documentation indicating proposed building height.
7. Additional drawings may be required based on the individual project.

Contact the City of Bethlehem Fire Department office at 610-865-7143, and request Fire Marshal Craig Baer, cbaer@bethlehem-pa.gov, or Chief Fire Inspector Michael Reich, mreich@bethlehem-pa.gov, with any questions or to obtain any documents required to complete the submittal for review.

ZONING

1. Include a statement of intent and indicate whether this is proposed as a rental community, condominium ownership or other.
2. Indicate within the Site Design Requirements Table actual building height; Ref. §1306.01(a)4.
3. Add to the Site Design Requirements Table a line for the maximum number of stories, Ref. §1306.01(a)4.
4. Within the Site Design Requirements Table correct Maximum Building Height Existing and Proposed to less than 35', i.e., <35'.
5. On the site plan, clarify if the 6' high wood fence along the northern and southern lot lines are existing or proposed.
6. Site/Record Plan General Notes, Note 12, correct "Town" to "City."
7. Add clear sight triangles along Rauch Street to the plans. Also include any proposed plantings, so as to demonstrate that the design will meet the requirements of §1318.06.
8. If refuse collection is to be centrally located, then indicate on the plan the dumpster pad and provide enclosure details; Ref. §1318.26(a).
9. Locate required bicycle parking on the plan, and include a note, "The current landowner shall be responsible to ensure that the hitch, rack or locker continues to be available and is well maintained and is replaced if damaged or removed," Ref. §1319.02(o).
10. Provide a driveway dimension at the curb line, Ref. §1319.03(c).
11. Provide dimensions from the paving to adjacent lot lines; Ref. §1322.02(c)(1)(ii).
12. Indicate if there will be a common mail box cluster, and if so, then locate the box on the plan; Ref. §1322.02(zz)(4).
13. A minimum of two (2) Street Trees are required per road frontage; Ref. §1319.02(j)(1).
14. Add a note to the plan indicating that the parcel is neither located within the Floodway nor Special Flood Hazard Area, and reference FEMA FIRM #42095C0307E, effective 7/16/2014.

GENERAL

1. Environment Advisory Council (EAC) comments will be included at the time of submission of Preliminary/Final Land Development.
2. Lehigh and Northampton Transportation Authority (LANTA) comments will be included at the time of submission of Preliminary/Final Land Development Plans.
3. The project should generally comply with the goals and objectives of the City's Climate Action Plan for new development, including energy efficient construction, provisions for safe walking and biking, green development and other various provisions.



CITY OF BETHLEHEM

Department of Fire
Office of the Fire Marshal

10 East Church Street, Bethlehem, Pennsylvania 18018-6025

www.bethlehem-pa.gov/fire

Phone: 610 865-7140

Fax: 610 997-5746

TDD: 610 865-7143

FIREPREVENTION@BETHLEHEM-PA.GOV

THE COUNCIL OF THE CITY OF BETHLEHEM HEREBY ORDAINS AS FOLLOWS:

SECTION 1. That Article 1501 of the Codified Ordinances of the City of Bethlehem, titled "Fire Safety and Code Enforcement Inspection Fees" as presently enacted is hereby restated and re-enacted as follows:

ARTICLE 1501

FIRE SAFETY AND CODE ENFORCEMENT INSPECTION FEES

- 1501.01 Authority
- 1501.02 Permits Required
- 1501.03 Inspection
- 1501.04 Adoption
- 1501.05 Modifications to 2018 International Fire Code

CROSS-REFERENCES

2018 International Fire Code - International Code Council
Article 150 of the Codified Ordinances of the City of Bethlehem - Codes Board of Appeals
Article 746 of the Codified Ordinances of the City of Bethlehem - Consumer Fireworks
DOT 49 CFR Parts 100-185 - United States Department of Transportation regulations
Optional Third Class City Charter Law Act of July 15, 1957, P.L. 901, as amended
Pennsylvania Uniform Construction Code 34 Pa.Code § 403

1501.01 AUTHORITY.

The City of Bethlehem Fire Department, Bureau of Inspections is hereby charged with the enforcement of this Article.

1501.02 PERMITS REQUIRED.

Permits required by the International Fire Code (current edition) shall be obtained from the Fire Code Official. Issued permits shall be kept on the premises designated therein at all times and shall be readily available for inspection by the Fire Code Official.

A fee for each permit shall be paid in accordance with the fee schedule as is set forth by resolution of Council of the City of Bethlehem, Pennsylvania.

1501.04 ADOPTION

Bethlehem Fire Department



CITY OF BETHLEHEM

Department of Fire
Office of the Fire Marshal

10 East Church Street, Bethlehem, Pennsylvania 18018-6025

www.bethlehem-pa.gov/fire

Phone: 610 865-7140

Fax: 610 997-5746

TDD: 610 865-7143

FIREPREVENTION@BETHLEHEM-PA.GOV

The 2018 International Fire Code (hereafter "IFC") published by the International Code Council, which is part of the Pennsylvania Uniform Construction Code pursuant to 34 Pa.Code § 403.21(a)(8), is hereby adopted in its entirety and made part of this Article subject to the modifications implemented hereinafter and/or by subsequent ordinance(s) of the City of Bethlehem (~~strikeouts~~ identify proposed deletions and underlined text identify proposed insertions to the 2018 IFC).

101.1 Title These regulations shall be known as the *FIRE CODE* of The City of Bethlehem, hereinafter referred to as "this code".

101.2.1 Appendices B, C, D, E, F, H, I, L, are adopted as part of this code.

1501.05 MODIFICATIONS TO 2018 INTERNATIONAL FIRE CODE.

(b) § 105.6.15 of the IFC shall be amended to read as follows:

105.6.15 Fire hydrants and valves. Approval from the Bethlehem Water Authority or its designee is required to use or operate fire hydrants or valves intended for fire suppression purposes which are installed on water systems and accessible to a fire apparatus access road that is open to or generally used by the public.

Exception: A permit is not required for authorized employees of the Bethlehem Water Authority or its designee that supplies the system or the fire department to use or operate fire hydrants or valves.

(d) § 105.6.39 of the IFC shall be amended to read as follows:

105.6.39 Private fire hydrants. Approval from the Bethlehem Water Authority and the Fire Code Official is required for the removal from service of private fire hydrants.

Exception: Approval from the Bethlehem Water Authority and the Fire Code Official is not required for private industry with trained maintenance personnel, private fire brigade or fire departments to maintain, test and use private hydrants.

(g) § 105.7.19 of the IFC shall be amended to read as follows:

105.7.19 Private Fire Hydrants. A construction permit is required for the removal or modification of private fire hydrants. Maintenance performed in accordance with this code is not considered to be a modification and does not require a permit.

(k) § 109.1 of the IFC shall be amended to read as follows:

Bethlehem Fire Department



CITY OF BETHLEHEM

Department of Fire
Office of the Fire Marshal

10 East Church Street, Bethlehem, Pennsylvania 18018-6025

www.bethlehem-pa.gov/fire
Phone: 610 865-7140
Fax: 610 997-5746
TDD: 610 865-7143
FIREPREVENTION@BETHLEHEM-PA.GOV

109.1 Board of appeals established. In order to hear and decide appeals of orders, decisions or determinations made by the fire code official relative to the application and interpretation of this code, the Board of Appeal identified in Article 150 of the Codified Ordinances of the City of Bethlehem and/or occasionally known as the "Codes Board of Appeals" shall have exclusive jurisdiction, subject to any right of further appeal therefrom.

- (m) The definition of the term "approved" found in IFC § 202 relating to General Definitions shall be amended to read as follows:

Approved. Acceptable to the fire code official, as evidenced by his/her written approval.

- (o) The definition of the term "fire code official" found in IFC § 202 relating to General Definitions shall be amended to read as follows:

FIRE CODE OFFICIAL. The fire chief or other designated authority, including the Fire Marshal of the City of Bethlehem, charged with the administration and enforcement of the code, or a duly authorized representative. The terms "Fire Marshal of the City of Bethlehem" and "Fire Code Official" shall be interchangeable in this and any other ordinance or resolution of the City of Bethlehem.

- (z) Add the following subsection to the IFC:

505.1.1 Only addresses approved and verified by the Department of Public Works Bureau of Engineering will be acceptable.

- (aa) § 507.3 of the IFC shall be amended to read as follows:

507.3 Fire flow. Fire flow requirements for buildings or portions of buildings and facilities shall be determined by an approved method determined by Department of Water and Sewer Resources.

507.3.1 Fire flow testing. The fire code official, Department of Water and Sewer Resources or its designees shall be notified prior to conducting fire flow testing. Fire flow tests shall be witnessed by the fire code official, Department of Water and Sewer Resources or its designees and approved documentation of the test and results shall be provided to the Department of Water and Sewer Resources.

- (bb) §507.4 of the IFC shall be amended to read as follows:

507.4 Water supply test. The fire code official and Department of Water and Sewer Resources or its designees shall be notified prior to the water supply test. Water supply tests shall be witnessed by the fire code official and Department of Water and Sewer Resources or its designees or approved documentation of the test shall be provided to Department of Water and Sewer Resources prior to final approval of the water supply system.



CITY OF BETHLEHEM

Department of Fire
Office of the Fire Marshal

10 East Church Street, Bethlehem, Pennsylvania 18018-6025

www.bethlehem-pa.gov/fire

Phone: 610 865-7140

Fax: 610 997-5746

TDD: 610 865-7143

FIREPREVENTION@BETHLEHEM-PA.GOV

507.4.1 The property owner is responsible for installation and maintenance of water supply for construction projects until the water system is accepted/approved by the Department of Water and Sewer Resources, and responsibility for the system is formally turned over to the Department of Water and Sewer Resources.

(cc) § 507.5.1 of the IFC shall be amended to read as follows:

507.5.1 Where required. Where a portion of the facility or building hereafter constructed or moved into or within the jurisdiction is more than 400 feet (122 m) from a hydrant on a fire apparatus access road, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains shall be provided where required by the fire code official and the Department of Water and Sewer Resources

Exceptions:

1. For Group R-3 and Group U occupancies, the distance requirement shall not be greater than 500 feet (152.4 m).
2. For buildings equipped throughout with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, the distance requirement shall not be greater than 500 feet (152.4 m).

(dd) Insert 901.6.3.2, 901.6.3.2.1, 901.6.3.2.2

901.6.3 Records. Records of all system inspections, tests and maintenance required by the referenced standards shall be maintained on the premises for a minimum of three years and shall be provided by the company performing the inspection(s) to the Office of the Fire Marshal, unless an alternate designee is specified by Resolution approved by the City Council of the City of Bethlehem.

Insert 901.6.3.2.1 Records shall be provided per City of Bethlehem Resolutions 2018-214 and 2018-222

Insert 901.6.3.2.2 Records shall be provided within 30 days of the date of inspection, testing, or maintenance

(ee) § 903.4.2 of the IFC is deleted in its entirety and replaced with the following:

903.4.2 Alarms. Approved audible devices shall be connected to every automatic sprinkler system. Such sprinkler waterflow alarm devices shall be activated by waterflow equivalent to the flow of a single sprinkler of the smallest orifice size installed in the system. Alarm devices shall be provided on the exterior of the building in an approved location. Where a fire alarm system is installed, actuation



CITY OF BETHLEHEM

Department of Fire
Office of the Fire Marshal

10 East Church Street, Bethlehem, Pennsylvania 18018-6025

www.bethlehem-pa.gov/fire

Phone: 610 865-7140

Fax: 610 997-5746

TDD: 610 865-7143

FIREPREVENTION@BETHLEHEM-PA.GOV

of the automatic sprinkler system shall actuate the building fire alarm system. In automatic sprinkler systems where multiple sprinkler risers are required, and the risers are located in separate areas within the building, an outside visible alarm notification appliance shall be required for each riser. Such appliance shall be a white strobe (minimum 95 candela strobe rating) placed in an approved location on the exterior wall, as close as practicable, to each sprinkler riser. The strobe will activate when the water flow alarm for its respective riser is activated.

(ff) The following subsection is added:

905.3.9. Large Area Buildings: The City requires Class I standpipes to access any portion of a building's interior which is more than 250 feet from the nearest approved point of fire department access or the nearest Class I standpipe connection. This distance shall be measured along a path of travel where fire hose can be deployed for fire suppression activities.

(gg) 905.4.1 Shall be modified to read:

905.4.1 In every required interior exit stairway, a hose connection shall be provided for each story above and below grade plane. Hose connections shall be located at an intermediate landing between stories, when present, unless otherwise approved by the fire code official

(hh) § 906.1 of the IFC shall be amended to read as follows:

906.1 Where required, portable fire extinguishers shall be installed in the following locations.

1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies without exception.



CITY OF BETHLEHEM

Department of Fire
Office of the Fire Marshal

10 East Church Street, Bethlehem, Pennsylvania 18018-6025

www.bethlehem-pa.gov/fire

Phone: 610 865-7140

Fax: 610 997-5746

TDD: 610 865-7143

FIREPREVENTION@BETHLEHEM-PA.GOV